



Facsimile Transmission


Date: 15-Oct-09	1	No of Pages (Including this sheet)	Pages	1	of	1
To : M/s. ABB,Dubai	Our Ref. : P-TR/OM/JHN/0291/09					
Fax No : 04-4380462	Subject : CE/448F/07 SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF LAKE TOWER-4 (AL MAFRAQ ROAD) 132/11KV SUBSTATION AND ASSOCIATED WORKS					
Attention: MR.KHURRAM HAFEEZ PROJECT MANAGER						

Material Approval for Cable Lugs and Gland


We refer to your correspondence No CE/448F/07/G5.2/MS/063 Dated 27th Sep/2009 regarding the Material Approval for Cable Lugs and Glands for the AlMafraq Road 132/11kV Substation.

Please be informed that the the type of above Cable Lugs and Glands from M/s High Grip,India is approved for Power Cables and Weidmuller for Control Cables.However,type test reports for power cable lugs shall be submitted.

This is for your information and further action,please.


15/10/09

(JIHAN MURAD HAJEEH)
PROJECT MANAGER-(TRANSMISSION)



British Safety Council