

Thursday 11th May 2017

M/s Ghantoot Transport & General Contracting Est.

P.O. Box, Abu Dhabi, UAE

Tel: 02 6414151

Fax: 02 6412010

Project ID : P1010AD
Client : Mr. Ali Al-Baloushi
Project : Mina Tower
Location : Plot No. C28, Sector E12, Abu Dhabi Corniche, UAE
Your Ref : GTGC-MT-SAF-102
Submission Date : 23rd April 2017
Actual Date : 13rd April 2017
Subject : Re: Material Submittal for Cable Glands and Lugs

Dear Sir,

Refer to the above project and submittal; please be informed that above said submittal having reviewed by us as below.

SUBMITTAL STATUS

Reviewed By

APPROVED
 APPROVED AS NOTED
 REVISE & RESUBMIT
 REJECTED

Client
 PEC

NOTE:

1. Size to be verified according to ADDC approved drawings.
2. Installation as per ADDC requirements.
3. Submit Sample for final approval.

This is for your information and kind Acton.

Best regards

Engr, Samy Sayed
General Manager
PIONEER Engineering Consultancy L.L.C

CC : Project Manager (PEC)
: Client

Transmission Method:

E-Mail Messenger Fax for Collection

SUBMITTAL APPROVAL FORM

MINA TOWER - PROJECT

23-04-17

SUBMITTAL FORM NO; GTGC-MT-SAF-102

REV;00

- MATERIAL TECHNICAL SHOP DRAWING SUBCONTRACTOR
 CIVIL MEP ARCH OTHERS

FROM:
Project Manager: Engr. Ahmad Mufti

Signature:

To:
PIONEER Engineering Consultancy.L.L.C

Supplied by Sub Contractor; ESS MIDDLE EAST GENERAL TRADING

MATERIAL SUBMITTAL

MODEL NO:	BOQ NO:	DESCRIPTION	
MANUFACTURER: HI GRIP	SL NO:	DRAWING NO:	
LOCATION OF USE:	1	GTGC/SAF/MT/MS-102	CABLE GLANDS & LUGS (Hi Grip)
<input type="checkbox"/>			
<input type="checkbox"/>			
<input type="checkbox"/> External <input type="checkbox"/> others			

CONTRACTOR MATERIAL ENGINEER/ QA/QC
Name:
Signature:

SUBMITTED FOR RECEIVED BY CONSULTANT

- ENCLOSURE NOS: 3 SETS +CD
- Manufacturer Technical Data Booklet
 - Catalogues
 - Original Brochures
 - Specification / B.O.Q/Vendor List
 - Recent test Reports/Certificate
 - Warranty Certificate/Trade License/ISO Certificate
 - Sample
 - Quotation
 - Compliance Check List
 - Shop Drawings
 - Complying Standards

- APPROVAL
- Review & Comment
- As Requested
- Information Only
- Record
- Revised & Resubmittal

Date:

PIONEER Comments

APPROVED → size to be verified according to ADDC ~~Acceptance~~ Approved Drawings.

APPROVED AS NOTED

REVISE & RESUBMIT

REJECTED → Installation As per ADDC Requirements.

ON HOLD

Reviewer of the Submittal: Ali Dajani DATE: 8/5/2017

Client Comments

APPROVED → sample for final approved.

APPROVED AS NOTED

REVISE & RESUBMIT

REJECTED

ON HOLD

Project Manager DATE:

Distribution: Owner Authority SUB Cont. RECEIVED BY: